

ENVIRONMENTAL PUBLIC RECORD



29 Hazen Drive, Concord, New Hampshire 03301 • (603) 271-3503 • www.des.nh.gov

Federally Regulated¹ Underground Storage Tanks in New Hampshire

Posted 1/26/2015

General Information

Total Number of Federally Regulated UST Facilities in NH: 1,142

Total Number of Federally Regulated USTs in NH: 2,975

Summary Information for On-Site Inspections - Inspection Period 10/1/2013 to 9/30/2014

Number of Federally Regulated UST Facilities Inspected: 386

Percentage of Federally Regulated UST Facilities Found in Compliance²: 47.2

Summary Information for Releases – Discovery Period 10/1/2013 to 9/30/2014

Number of Confirmed Federally Regulated UST Releases: 27

Summary Information for Federally Regulated UST Release Sources and Causes

SOURCE																
			Spill		Overfill		Phys/Mech Damage		Corrosion		Installation Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	1	4%			1	100%										
Piping	0	0%														
Dispenser	11	41%			6	55%	1	9%					1	9%	3	27%
STP	0	0%														
Delivery Problem	3	11%	3	100%												
Other	3	11%	3	100%												
Unknown	9	33%	1	11%											8	89%
Totals	27	100%	7	26%	7	26%	1	4%	0	0%	0	0%	1	4%	11	41%

Public site specific information about underground storage tank facility compliance and/or releases may be found on the State of New Hampshire OneStop data retrieval site at <http://www2.des.state.nh.us/DESONestop/BasicSearch.aspx>

¹A Federally regulated underground storage tank includes those tanks containing motor fuel such as gasoline and diesel for dispensing, motor fuel for use in electrical generators, and hazardous substances as defined in RSA 146-C:1, VII-a.

²The percentage of Federally regulated UST facilities found to be in significant operational compliance with both the spill, overfill, and corrosion protection requirements and the leak detection requirements of the New Hampshire Code of Administrative Rules, Env-Or 400, Underground Storage Tank Facilities <http://des.nh.gov/organization/commissioner/legal/rulemaking/documents/env-or400-adptd-pstd.pdf> at the time of the state inspection

Information contained in this Public Record is current as of January 26, 2015. If there are any questions concerning the status of this information, please contact DES at (603) 271-3899.